



# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: **IECEx FMG 14.0032X**

Page 1 of 4

Certificate history:

Status: **Current**

Issue No: 13

[Issue 12 \(2022-04-01\)](#)

[Issue 11 \(2021-09-02\)](#)

[Issue 10 \(2020-11-30\)](#)

[Issue 9 \(2020-04-20\)](#)

[Issue 8 \(2020-03-30\)](#)

[Issue 7 \(2020-02-25\)](#)

[Issue 6 \(2019-10-16\)](#)

[Issue 5 \(2018-09-24\)](#)

[Issue 4 \(2017-03-20\)](#)

[Issue 3 \(2016-11-30\)](#)

Date of Issue: 2022-12-05

Applicant: **Temposonics LLC**  
3001 Sheldon Drive  
Cary NC 27513  
**United States of America**

Equipment: **Level Plus Transmitters**

Optional accessory: Level Plus Digital Level Transmitters, Level Plus Analog Level Transmitters. (Tank Slayer, RefineME, SoClean, Chambered, LevelLimit)

Type of Protection: **Intrinsic Safety "ia"**

Marking: Ex ia IIC T4 Ga  
Ta=-50°C to 71°C; IP65

Approved for issue on behalf of the IECEx  
Certification Body:

**J.E.Marquedant**

Position:

**VP, Manager - Electrical Systems**

Signature:  
(for printed version)

Date:  
(for printed version)

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting [www.iecex.com](http://www.iecex.com) or use of this QR Code.



Certificate issued by:

**FM Approvals LLC**  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
**United States of America**





# IECEx Certificate of Conformity

Certificate No.: **IECEx FMG 14.0032X**

Page 2 of 4

Date of issue: 2022-12-05

Issue No: 13

Manufacturer: **Temposonics LLC**  
3001 Sheldon Drive  
Cary NC 27513  
**United States of America**

Manufacturing  
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

## STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

**IEC 60079-0:2017** Explosive atmospheres - Part 0: Equipment - General requirements  
Edition:7.0

**IEC 60079-11:2011** Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"  
Edition:6.0

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

## TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

US/FMG/ExTR14.0035/00  
US/FMG/ExTR14.0035/03  
US/FMG/ExTR14.0035/06  
US/FMG/ExTR14.0035/09  
US/FMG/ExTR14.0035/12

US/FMG/ExTR14.0035/01  
US/FMG/ExTR14.0035/04  
US/FMG/ExTR14.0035/07  
US/FMG/ExTR14.0035/10  
US/FMG/ExTR14.0035/13

US/FMG/ExTR14.0035/02  
US/FMG/ExTR14.0035/05  
US/FMG/ExTR14.0035/08  
US/FMG/ExTR14.0035/11

Quality Assessment Report:

GB/FME/QAR14.0005/08



# IECEx Certificate of Conformity

Certificate No.: **IECEx FMG 14.0032X**

Page 3 of 4

Date of issue: 2022-12-05

Issue No: 13

## EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

**Level Plus Digital Level Transmitters. (Tank Slayer, RefineME, SoClean, Chambered, LevelLimit)**

**Level Plus Analog Level Transmitters. (Tank Slayer, RefineME, SoClean, Chambered, LevelLimit)**

## SPECIFIC CONDITIONS OF USE: YES as shown below:

### X-Marking

1. The apparatus enclosure contains aluminum or titanium and is considered to constitute a potential risk of ignition by impact or friction. Care must be taken into account during installation and use to prevent impact or friction. (*When installed in a Ga Approval*)
2. The maximum permitted ambient temperature of the Level Plus Digital/Analog Level Transmitter is 71 °C. To avoid the effects of process temperature and other thermal effects care shall be taken to ensure the surrounding ambient and the ambient inside the transmitter housing does not exceed 71°C
3. Some models contains non-metallic enclosure parts, to prevent the risk of electrostatic sparking the non-metallic surface should only be cleaned with a damp cloth.



# IECEx Certificate of Conformity

Certificate No.: **IECEx FMG 14.0032X**

Page 4 of 4

Date of issue: 2022-12-05

Issue No: 13

**DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)**

Revised drawings to accommodate UKEX markings.

**Annex:**

[Annex to certificate IECEx FMG 14.0032X.pdf](#)

## **Annex to IECEx Certificate IECEx FMG 14.0032X**

### **Level Plus Digital Level Transmitters. (Tank Slayer, RefineME, SoClean, Chambered)**

#### Entity Parameters:

Supply:  $U_i = 28\text{ V}$ ,  $I_i = 100\text{ mA}$ ,  $C_i = 0\text{ }\mu\text{F}$ ,  $L_i = 0\text{ mH}$ ,  $P_i = 700\text{ mW}$

Rx/Tx-:  $U_i = 8.6\text{ V}$ ,  $I_i = 10\text{ mA}$ ,  $C_i = 0\text{ }\mu\text{F}$ ,  $L_i = 0\text{ mH}$ ,  $P_i = 21.5\text{ mW}$

Rx/Tx+:  $U_i = 8.6\text{ V}$ ,  $I_i = 10\text{ mA}$ ,  $C_i = 0\text{ }\mu\text{F}$ ,  $L_i = 0\text{ mH}$ ,  $P_i = 21.5\text{ mW}$

#### **LPabcdefghijklmnop.**

a = Unit: T, R, C or S

b = Output: M, D or U

c = Housing Type: A, B, C, D, E, L or Y

d = Electronics mounting: 1, 2, 3, 4, 5, 6, 7 or 8

e = Sensor Pipe: B, C, D, E, F, M, N, P, S, R, Y or X

f = Material of Construction: 1, 2, 3, A or 9

g = Process Connection Type: 1, 2, 4, 5, 6, 7, 8, A, B, C, D or X

h = Process Connection Size: A, B, C, D, E, F, G, H, J or X

i = Number of DT's: 0, 1, 5, K, M, P or X

j = DT Placement: F, C, B, E, K or X

k = Notified Body: I

l = Protection Method: I

m = Gas Group: 3

n = Units of Measure: F, M or U

o = Length: (numeric)

p = Special: S, E, R or F

### **Level Plus Analog Level Transmitters. (Tank Slayer, RefineME, SoClean, Chambered)**

#### Entity Parameters:

Loop 1:  $U_i = 28\text{ Vdc}$ ,  $I_i = 120\text{ mA}$ ,  $P_i = 840\text{ mW}$ ,  $L_i = 5\text{ }\mu\text{H}$ ,  $C_i = 0\text{ }\mu\text{F}$

Loop 2:  $U_i = 28\text{ Vdc}$ ,  $I_i = 120\text{ mA}$ ,  $P_i = 840\text{ mW}$ ,  $L_i = 5\text{ }\mu\text{H}$ ,  $C_i = 0\text{ }\mu\text{F}$

#### **LPabcdefghijklmnop.**

a = Unit: T, R, C or S

b = Output: 1, 2, 3, 4, 5, 6 or 7

c = Housing Type: A, B, C, D, E, L or Y

d = Electronics mounting: 1, 2, 3, 4, 5, 6, 7 or 8

e = Sensor Pipe: B, C, D, E, F, M, N, P, S, R, Y or X

f = Material of Construction: 1, 2, 3, A or 9

g = Process Connection Type: 1, 2, 4, 5, 6, 7, 8, A, B, C, D or X

h = Process Connection Size: A, B, C, D, E, F, G, H, J or X

i = Number of DT's: 0, 1, 5, K, M, P or X

j = DT Placement: F, C, B, E, K or X

k = Notified Body: I

l = Protection Method: I

m = Gas Group: 3

n = Units of Measure: F, M or U

o = Length: (numeric)

p = Special: S, E, R or F

### **Level Plus Digital Level Transmitters. (LevelLimit)**

#### Entity Parameters:

Supply:  $U_i = 28\text{ V}$ ,  $I_i = 100\text{ mA}$ ,  $C_i = 0\text{ }\mu\text{F}$ ,  $L_i = 0\text{ mH}$ ,  $P_i = 700\text{ mW}$   
Rx/Tx-:  $U_i = 8.6\text{ V}$ ,  $I_i = 10\text{ mA}$ ,  $C_i = 0\text{ }\mu\text{F}$ ,  $L_i = 0\text{ mH}$ ,  $P_i = 21.5\text{ mW}$   
Rx/Tx+:  $U_i = 8.6\text{ V}$ ,  $I_i = 10\text{ mA}$ ,  $C_i = 0\text{ }\mu\text{F}$ ,  $L_i = 0\text{ mH}$ ,  $P_i = 21.5\text{ mW}$   
Switch:  $U_i = 28\text{ Vdc}$ ,  $I_i = 5\text{ mA}$ ,  $C_i = 0\text{ }\mu\text{F}$ ,  $L_i = 7.59\text{ mH}$ ,  $P_i = 140\text{ mW}$

#### **LPLbcdefghijklmn**

b = Output; M  
c = Sensor Pipe; B, M, N, P or S  
d = Process Connection Type; 1, 6, 7, 8, A, B, C, D, Z or X  
e = Process Connection Size; A, B, D, E, F, G, H, J or X  
f = Number of Digital Thermometers; 0, 1, 5, K, M, P or X  
g = DT Placement; C, F or X  
h = Notified Body; I  
i = Protection Method; I  
j = Gas Group; 3  
k = Unit of Measure; F, M or U  
l = Length; any 5 numerical digits  
m = Special; S, E, R or F  
n = HI Switch Position; any 5 numerical digits

### **Level Plus Analog Level Transmitters. (LevelLimit)**

#### Entity Parameters:

Loop 1:  $U_i = 28\text{ Vdc}$ ,  $I_i = 120\text{ mA}$ ,  $P_i = 840\text{ mW}$ ,  $L_i = 5\text{ }\mu\text{H}$ ,  $C_i = 0\text{ }\mu\text{F}$   
Loop 2:  $U_i = 28\text{ Vdc}$ ,  $I_i = 120\text{ mA}$ ,  $P_i = 840\text{ mW}$ ,  $L_i = 5\text{ }\mu\text{H}$ ,  $C_i = 0\text{ }\mu\text{F}$   
Switch:  $U_i = 28\text{ Vdc}$ ,  $I_i = 5\text{ mA}$ ,  $P_i = 140\text{ mW}$ ,  $L_i = 7.59\text{ mH}$ ,  $C_i = 0\text{ }\mu\text{F}$

#### **LPLbcdefghijklmn**

b = Output; 1, 2, 5 or 7  
c = Sensor Pipe; B, M, N, P or S  
d = Process Connection Type; 1, 6, 7, 8, A, B, C, D, Z or X  
e = Process Connection Size; A, B, D, E, F, G, H, J or X  
f = Number of Digital Thermometers; 0, 1, 5, K, M, P or X  
g = DT Placement; C, F or X  
h = Notified Body; I  
i = Protection Method; I  
j = Gas Group; 3  
k = Unit of Measure; F, M or U  
l = Length; any 5 numerical digits  
m = Special; S, E, R or F  
n = HI Switch Position; any 5 numerical digits